

Minutes of the Pre Bid Meeting

Supply, Installation and Commissioning of 250kVA, 230/400V and 50 Hz Diesel Generator for Faculty of Technological Studies Uva Wellassa University of Sri Lanka

Bid No : UWU/G/NCB/20/03

Date : 15th December 2020

Venue : Bursar's Office

At the Pre Bid Meeting following clarification were made against the bidders requests.

Silencer System – Need to provide approx 6m high from generator with SS304 (Stainless Steel) or higher grade with suitable diameter.

Clear Width – The clear width of the area where generator to be placed, is approx. 3.4m which the bidder shall consider for openable sashes and working space.

Cabelling details – Please refer the attached drawing.



Chairman
Department Procurement Committee
Uva Wellassa University