

Addendum No 01

Minutes of the pre bid meeting of the Construction of Alternative Anatomy Lab for Faculty of Medicine of Uva Wellassa University of Sri Lanka

Date: 28/08/2023

Time: 10.00 a.m.


Venue: Maintenance Division of the Uva Wellassa University

Deputy Registrar(C/W) welcomed the members of the TEC and the bidders to the pre bid meeting. During the meeting, following clarifications were notified to the bidders.

- Aluminum works - All the glass panels shall be with 5mm thick clear glass.
- Vinyl flooring material shall be with abrasion resistant and chemical resistant.
- Roof covering : Mass of Zn /Al coating/g/m² on both sides is 140 or above. Tensile strength - 490MPa or above.
- Value of input weightage for price escalation;

L-1	Skilled labour	12.13%	M-27	Wall paint	2.36%
L-3	Unskilled labour	9.89%	M-13	R/f Steel & metal	2.84%
P-1	Small equipment	2.28%	M-36	Aluminum	27.38%
P-2	Heavy equipment	2.87%	M-26	Electrical works	5.34%
M-4	Cement & flooring	8.68%	M-37	Ceiling work	7.91%
M-8	Sand	0.69%	M-20	Plumbing(lay)	1.02%
M-7	Metal(agg)	0.85%	M-19	Sanitary Fittings	2.49%
M-6	Rubble	0.31%	M-21	Formwork	1.23%
M-9	Brick	1.39%	M-xx	Fire Protection system	0.37%

A site visit was made after the meeting with all the participants to make aware about the location, the ground conditions, physical topography etc.,

Signed By:

Deputy Registrar
Capital Works Division
Uva Wellassa University