

## **Addendum No.01**

**Minutes to the pre bid meeting of Supply, Delivery, Installation and Commissioning of Lab Furniture, Equipment and Other Items for Anatomy Laboratory, Faculty of Medicine, Uva Wellassa University**

**Date:** 10.10.2023

**Time:** 10.00 a.m.

**Venue:** Faculty of Medicine, Uva Wellassa University

**Ref No:** UWU/G/NCB/FOM/23/02

The Deputy Bursar (Stores and Supplies) welcomed the members of the TEC and bidders to the pre bid meeting. During the meeting following clarifications were notified to the bidders.

- **Technical Specifications**

- **Package 02**

- **Item No. 11- Tanks for Storing Cadavers**

- Structure will be 306 grade stainless steel or better
      - 06 nos castors with approx. 50 mm diameter and Heavy duty use
      - Sheet thickness should be 1.2 mm or higher
      - Cadavers should be operated with 2500 kg or higher weight
      - Formalin resistant insulated lids
      - Wash out provision need to provide with relevant connectors to drainage line
      - Warranty – 3 years

- **Item No. 12 - Autopsy Tables**

- Stainless Steel [ 84(L) x 36(W) x 30(H) inches or equal] with one (01) inches right round ledges and collecting chamber
      - Collecting chamber capacity around 5L
      - Table top should sloped towards the collecting chamber
      - Sheet thickness should be 1.2 mm or higher with SS 306 or higher grade
      - 04 nos castors with approx. 50 mm diameter and Heavy duty use
      - Wash out provision need to provide with relevant connectors to drainage line
      - Cadavers should be operated with 150 kg weight

- **Item No.13 - Trolleys**

- Finish – 306 grade stainless steel or better

**Package 03**

- **Item No.14 - Dissection Trays**
  - Stainless steel 16''(L) x 12'' (W) , 30'' (H) with 0.5 mm thickness or higher
- **Item No.15 - Plastic Buckets**
  - Capacity 65 L with Lid
- **Item No.35 - Band Saw Heavy Duty Bone cutter**
  - Standard with 05 nos band saw with the item
- **Item No.40 - Binocular Microscope**
  - Other Features
    - I. Should provide with dust cover, immersion oil.
    - II. Should work with input 200 to 230V +/- 10% AC and 50 Hz supply.
- **Item No.41 - Post Mortem Instruments set (Autopsy) for lecturers' Dissections**
  - Standard
- **Item No.42 - Illuminators (4 in one)**
  - changed as "X-ray Illuminators (4 in one)"
- **Note 01: for all stainless steel items**
  - Stainless Steel 306 grade or higher is required for the items of all stainless excluding item No.16- 34
  - Stainless Steel 316 grade is required for the item No.16- 34

  
Deputy Bursar

(Stores & Supplies)

Uva Wellassa University

**Deputy Bursar  
Stores & Supplies**

**Uva Wellassa University  
Passara Road, Badulla.**